MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

Town of Jumpertown
Public Water System Name

0590009
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION *(Check all boxes that apply.)*

INDIRECT DELIVERY METHODS *(Attach copy of publication, water bill or other)*	DATE ISSUED
☐ Advertisement in local paper *(Attach copy of advertisement)*	
☐ On water bills *(Attach copy of bill)*	
☐ Email message *(Email the message to the address below)*	
☒ Other Enclose CCR Water Bill	6-1-2021
DIRECT DELIVERY METHOD *(Attach copy of publication, water bill or other)*	**DATE ISSUED**
☒ Distributed via U. S. Postal Mail	5-28-2021
☐ Distributed via E-Mail as a URL *(Provide Direct URL):*	
☐ Distributed via E-Mail as an attachment	
☐ Distributed via E-Mail as text within the body of email message	
☐ Published in local newspaper (attach copy of published CCR or proof of publication)	
☐ Posted in public places (attach list of locations)	
☐ Posted online at the following address *(Provide Direct URL):*	

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Donna Hickman	City Clerk	6-7-21
Name	Title	Date

SUBMISSION OPTIONS *(Select one method ONLY)*

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800 (NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 Annual Drinking Water Quality Report
Jumpertown Water Dept.
PWS ID# 0590009
May 13, 2021

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two wells. Our wells draw from the Gordo Formation.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are **moderate** susceptibility to contamination and is available for viewing upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Donna Hickman at (662) 728-3658. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 P.M. at the Town Hall.

Jumpertown Water Dept. routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2020. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Disinfectants & Disinfection By-Products (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl2) (ppm)	N	2020	.80—1.10	1.0	Ppm	4	4	Water additive used to control microbes
Inorganic Contaminants								
Chromium	N	*2016	1.6	No-range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Barium	N	*2019	02624	0.244-0.2624	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Lead	N	1/01/--12/31/20	1.0	No-Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Fluoride	N	*2019	0.108-	.105--.018	Ppm	4.0	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Cyanide	N	*2016	27.0	No-Range	Ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Copper	N	1/01/--12/31/20	0.4	.01--.49	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Volatile Organic Contaminants								
TTHM (total trihalomemethanes	N	2019	2.7	No-range	Ppb	0	80	By-product of drinking water chlorination
HAA5	N	2020	6.0	No-Range	Ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants								
Sodium	N	2019	120,000	9300, -120,000	Ppb	0	60	By-product of drinking water chlorination

*Most recent sample. No sample was required in 2020

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **Town of Jumpertown** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call 662-728-3658 if you have any questions.

TOWN OF JUMPERTOWN
679 HWY 4 WEST
BOONEVILLE MS 38829
(662)728-3658

ACCOUNT NO. 02-0113000

BALANCE DUE BY 06/10/2021 29.22
LAST PAY DATE: 05/10/2021
LAST PAY AMT: 29.05-

JESSE ADAMS 114

114 WESTOVER HEIGHTS
BOONEVILLE, MS 38829

AMOUNT DUE (AFTER 10TH) 32.04

RETURN THIS PORTION WITH
YOUR PAYMENT

- PAY ONLINE - AT www.govpaynow.com PLC# a0034a

SERVICE ADDRESS	SERVICE PERIOD	ACCOUNT NUMBER
114 WESTOVER HEIGHTS	04/15/2021 THRU 05/19/2021	02-0113000

ACCOUNT AGEING

CURRENT	29.22
30 DAY	0.00
60 DAY	0.00
90 DAY & OVER	0.00

USAGE HISTORY

JUN 2021	MAY 2021	APR 2021
4920	492	4870

SERVICE	CURRENT CHARGE	METER READINGS PREVIOUS	PRESENT	USAGE
PAST DUE	29.22	167100	172020	4920
AMOUNT DUE	29.22	167100	172020	4920
LC (APPLIED AFTER 10TH)	2.82	167100	172020	4920
AMOUNT DUE (AFTER 10TH)	32.04	167100	172020	4920

CUT-OFF IS 5:00 PM ON 20TH.
BILL NOT PAID A $50.00 MAINT.

PLEASE REMIT PAYMENT BY 06/10/2021 TO AVOID A LATE CHARGE.

$50.00 RECONNECTION FEE DUE IF METER IS LOCKED FOR NON-PAYMENT.

EQUAL OPPORTUNITY UTILITY SERVICE PROVIDER

TOWN OF JUMPERTOWN
679 HWY 4 WEST
BOONEVILLE MS 38829
(662)728-3658